

JOHN F. KENNEDY ELEMENTARY

1310 RATZER ROAD

KEY : TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: NONE DETECTED BS: BELOW DEP / EPA STANDARD

TEST DATES : 6/2/16 & 9/6/16

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6428036-4	BOYS RM 2ND FL SINK 4	SIGN POSTED	TNR
L6428036-5	GIRLS RM 2ND FL SINK 2	3.500	TNR/BS
L6428036-6	CLASSROOM 18 SINK	6.100	TNR/BS
L6428036-7	CLASSROOM 17 SINK	3.200	TNR/BS
L6428036-8	GIRLS RM 2ND FL SINK 4	4.400	TNR/BS
L6428036-9	CLASSROOM 14 SINK	4.700	TNR/BS
L6428036-10	WATER FOUNTAIN LEFT MEDIA CENTER	7.800	BS
L6428036-11	BATHROOM SINK NEXT BOYS RM 2ND FL	SIGN POSTED	TNR
L6428036-12	CLASSROOM 20 SINK	4.600	TNR/BS
L6428036-13	WOMENS ROOM SINK INSIDE GIRLS RM	3.200	TNR/BS
L6428036-14	CLASSROOM 19 SINK	5.000	TNR/BS
L6428036-15	CLASSROOM 16 SINK	8.700	TNR/BS
L6428036-16	BOYS RM 2ND FL SINK 3	2.400	TNR/BS
L6428036-17	CLASSROOM 23 SINK	4.000	TNR/BS
L6428036-18	CLASSROOM 22 SINK	1.000	TNR/BS
L6428036-19	BOYS RM 2ND FL SINK 1	2.900	TNR/BS
L6428036-20	GIRLS RM 2ND FL SINK 3	3.300	TNR/BS
L6428036-21	CLASSROOM 12 SINK	9.700	TNR/BS
L6428036-22	GIRLS ROOM 2ND FL SINK 2	4.100	TNR/BS
L6428036-23	SLOP SINK NEXT TO GIRLS RM 2ND FL	1.100	TNR/BS
L6428036-24	BOYS RM 2ND FL SINK 2	3.000	TNR/BS
L6428036-25	FOUNTAIN NEXT TO GIRLS RM 2ND FL	2.400	BS
L6428036-26	CLASSROOM 13 SINK	5.800	TNR/BS
L6428036-27	CLASSROOM 8 SINK	10.800	TNR/BS
L6428036-28	GIRLS RM BY CUSTODIAN OFFICE SINK RIGHT	4.200	BS
L6428036-29	BOYS RM BY CUSTODIAN OFFICE SINK RIGHT	3.700	BS
L6428036-30	STAFF ROOM SINK	2.100	BS
L6428036-31	BOILER ROOM SINK	4.800	TNR/BS
L6428036-32	CLASSROOM 32 SINK	1.800	TNR/BS
L6428036-33	KITCHEN SINK ON ISLAND	0.830	BS
L6428036-34	WATER FOUNTAIN BY MUSIC ROOM	0.560	BS
L6428036-35	KITCHEN SINK ON WALL MIDDLE	2.300	BS
L6428036-36	CLASSROOM 7 FOUNTAIN	1.700	BS
L6428036-37	KITCHEN SINK ON WALL LEFT	5.700	BS
L6428036-38	MENS RM SINK BY MUSIC ROOM	3.300	TNR/BS
L6428036-39	CLASSROOM 6 SINK	4.600	TNR/BS

JOHN F. KENNEDY ELEMENTARY**1310 RATZER ROAD****KEY : TNR: TESTING NOT REQUIRED****DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION****ND: NONE DETECTED BS: BELOW DEP / EPA STANDARD****TEST DATES : 6/2/16 & 9/6/16**

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6428036-40	CLASSROOM 1 FOUNTAIN	4.600	BS
L6428036-41	LADIES RM SINK BY MUSIC ROOM	2.200	TNR/BS
L6428036-42	KITCHEN SINK ON WALL RIGHT	3.600	BS
L6428036-43	BOYS RM BY CUSTODIAN OFFICE SINK LEFT	2.400	TNR/BS
L6428036-44	NURSES OFFICE SINK	3.600	BS
L6428036-45	CLASSROOM 3 SINK	9.200	TNR/BS
L6428036-46	CLASSROOM 1 SINK	6.300	TNR/BS
L6428036-47	CLASSROOM 10 FOUNTAIN	1.800	BS
L6428036-48	CLASSROOM 4 FOUNTAIN	0.820	BS
L6428036-49	CLASSROOM 9 SINK	3.100	TNR/BS
L6428036-50	CLASSROOM 4 SINK	2.100	TNR/BS
L6428036-51	CLASSROOM 7 SINK	6.100	TNR/BS
L6428036-52	MUSIC ROOM SINK	5.100	BS
L6428036-53	GIRLS ROOM SINK LEFT BY CUSTODIAN	2.700	TNR/BS
L6428036-54	CLASSROOM 5 SINK	9.000	TNR/BS
L6428036-55	CLASSROOM 11 SINK	6.200	TNR/BS
L6428036-56	UNISEX BATHROOM SINK BY RM 36	1.800	TNR/BS
L6428036-57	CLASSROOM 10 SINK	2.000	TNR/BS
L6428036-58	CLASSROOM 8 FOUNTAIN	1.800	BS
L6428036-59	MEDIA CENTER OFFICE SINK	8.000	BS